

Newport News Waterworks  
Lightfoot System  
2019 Lead and Copper Data

Sample ID	Pb, ug/L	Cu, ug/L
LF01	2.15	24.1
LF03	0	17.6
LF04	0	18
LF07	1.18	23.3
LF08	0	21.3
LF12	0	25.1
LF16	0	22.7
LF19	0	30.4
LF20	0	19.9
LF22	0	24.2
LF23	1.15	24.2
LF24	0	13.4
LF28	0	12.6
LF29	0	62.4
LF30	0	51.5
LF32	0	34.4
LF33	0	23.6
LF36	0	20.5
LF40	0	13.9
LF45	2.06	38.2
LF46	0	34.1
90th Percentile	1.18	37.9
Min	0	12.6
Max	2.06	62.4
Median	0	23.45
# Samples	21	21