

Sanitary Sewer Overflow Report for 2022

Incident Number	Responsible Party	Site Name	Site Address	Description of Incident	Incident Date	Amount Reaching State Waters (gallons)
106118	City Of Newport News	520 Ivy Ave	520 Ivy Ave.	Main Line Stoppage.	04/19/22	525
106119	City Of Newport News	12943 Jefferson Ave	12943 Jefferson Ave.	Main Line Stoppage	04/19/22	5,150
106128	City Of Newport News	450 Eastwood Dr.	450 Eastwood Dr.	leaking at Manhole in road.	05/04/22	450
106136	City of Newport News	Pump Station #53	124 Rexford Dr.	Bypass pump hose failure spilled raw sewage into low lying wooded area in front of station.	06/06/22	25,000
106138	City of Newport News	Pump Station #71	5601 Patricia Dr.	Bypass pump hose failure released sewage into ditch.	06/07/22	20,000
106139	Carolina Marine Contractors	Happy Creek Project	432 Maryle Ct.	Contractor working on City project buried excavator in mud which was over top of sewer main, consequently breaking sewer main. After break they set up a small pump discharging back into sanitary system. Impossible to verify exact amount lost or recovered.	06/07/22	20,000
106162	City pf Newport News	PS 43	398 Flint Dr.	Large amount of rags and grease chunks clogging downstream pipe. Incident recorded on Cityworks SR# 655003, WO# 468317. SSO documented on Cityworks WO# 468318.	08/06/22	1,600
106169	City pf Newport News	Pump Station 071	31 Williamson Park Dr.	Large amount of grease clogging downstream pipe.	09/03/22	1,750
106187	City of Newport News	1310 Gatewood Rd	1310 Gatewood Rd.	Mainline stoppage caused by grease/debris	10/12/22	2,700